

TUTORIAL-05: COST TARGETING

Based on **Lecture-21: Cost targeting**

Problem 1: Compute the cost targeted for stream data shown in Table 1, where two hot streams exchange heat against a single cold stream assuming ΔT_{\min} as 10°C . The overall heat transfer coefficient, U , is constant and is equal to $0.123 \text{ kW}\cdot\text{m}^{-2}\text{K}^{-1}$ for all exchangers.

Table 1: Stream data for Problem 1

stream	Supply temperature, T_s ($^{\circ}\text{C}$)	Target temperature, T_t ($^{\circ}\text{C}$)	Heat capacity flow rate, CP ($\text{kW}\cdot^{\circ}\text{C}^{-1}$)
HOT (H1)	180	140	1.4
HOT (H2)	150	90	2.5
COLD (C1)	70	150	4

Given:

(a) The capital cost of the individual heat exchangers is according to following relationship:

$$\text{Heat exchanger capital cost (\$)} = 30,000 + 400 (A)^{0.9}$$

Where, A is the heat transfer area of exchanger in m^2 .

(b) The utility costs are:

$$\text{Steam cost} = 120,000 (\text{\$.kW}^{-1}\cdot\text{y}^{-1})$$

$$\text{Cooling water cost} = 10,000 (\text{\$.kW}^{-1}\cdot\text{y}^{-1})$$

(c) Plant life and rate of interest are assumed as 5 years and 10%, respectively.

Solution 1: To target the cost for stream data shown in Table 1 first area is targeted as shown for Problem 1 of Tutorial-03, which comes out to be 68.866 m^2 .

Now cost targeting can be described as -

a) Capital cost targeting

$$\text{Capital cost} = 30,000 + 400 (A)^{0.9} = 30,000 + 400 (68.866)^{0.9} = 48041.156$$

Conversion of the capital cost into annual capital cost :

$$\text{Conversion factor} : \frac{i(1+i)^n}{(1+i)^n - 1}$$

where n and i are 5 and 10, respectively.

So the annual capital cost is computed as:

Annual capital cost = Capital cost * Conversion factor

$$\begin{aligned} &= 48041.156 * \frac{0.1 * (1 + 0.1)^5}{(1 + 0.1)^5 - 1} \\ &= 12673.1359 \text{ \$yr}^{-1} \end{aligned}$$

b) Operating cost targeting

For the present problem hot and cold utility are found as 114 kW and 0 kW, respectively, as computed for Problem 1 of Tutorial-03. Thus,

$$\text{Hot utility cost} = 114 * 120,000 = 13680.00 \text{ \$} \cdot \text{yr}^{-1}$$

Similarly,

$$\text{Cold utility cost} = 0 * 10,000 = 0 \text{ \$} \cdot \text{yr}^{-1}$$

Thus, total annual operating cost is 13680\$.yr⁻¹.

c) Total Annual Cost (TAC) Targeting

TAC = Annual capital cost + Annual operating cost

$$= 13680 + 12673.1359 = 26353.1359$$

So, Total annual cost is targeted as \$ 26353.1359/yr.

Problem 2: For a process the stream data, together with utility data and heat transfer coefficients are shown in Table 2, where ΔT_{\min} is selected as 10 °C. Steam from 250°C to 249°C is used as hot utility whereas cold water from 25°C to 35°C is used as cold utility. Target the cost for this process.

Table 2: Complete stream and utility data for the process

Stream	Supply temperature T_s (°C)	Target temperature T_T (°C)	ΔH (MW)	Heating capacity flow rate, CP (MW.°C ⁻¹)	Film heat transfer coefficient, h (MW.m ⁻² .°C ⁻¹)
Cold (C1)	25	185	32.0	0.25	0.0008
Hot (H1)	260	50	-31.5	0.16	0.0009
Cold (C2)	145	235	27.0	0.32	0.0009
Hot (H2)	190	70	-30.0	0.26	0.0010
Steam (HU)	250	249			0.0040
Cold water (CU)	25	35			0.0010

Given:

$$\text{Cost of hot utility} = 150 (\$.kW^{-1}.y^{-1})$$

$$\text{Cost of cold utility} = 15 (\$.kW^{-1}.y^{-1})$$

$$\text{Installed capital cost} = 40000 * A^{0.83}$$

$$\text{Rate of interest} = 12\%$$

$$\text{Plant life} = 6 \text{ year}$$

Solution 2: To calculate the cost for stream data shown in Table 2, total area is targeted first, which is 6520.636 m² as shown for Problem 2 of Tutorial-03.

Now the total cost targeting is described below:

a) Capital cost targeting

$$\text{Capital cost targets (\$)} = 40000 * (A)^{0.83} = 40000 * (6520.636)^{0.83} = 58603108$$

Conversion of the capital cost into annual capital cost:

$$\text{Conversion factor} = \frac{i(1+i)^n}{(1+i)^n - 1}$$

where n and i are 6 and 0.12, respectively.

Thus, the annual capital cost is computed as:

Annual capital cost = Capital cost * Conversion factor

$$\begin{aligned} &= 58603108 * \frac{0.12 * (1 + 0.12)^6}{(1 + 0.12)^6 - 1} \\ &= 14253783.05 \text{ \$yr}^{-1} \end{aligned}$$

b) Operating cost targeting

For the present problem hot and cold utility are found as 12.9 MW and 8.90 MW, respectively, as computed for Problem 1 of Tutorial-03. Thus,

$$\text{Hot utility cost} = 12900 * 150 = 1935000 \text{ \$}.\text{yr}^{-1}$$

Similarly,

$$\text{Cold utility cost} = 8900 * 15 = 133500 \text{ \$}.\text{yr}^{-1}$$

Thus the total annual operating cost is 2068500 $\text{\$.yr}^{-1}$

c) Total Annual Cost (TAC) Targeting

$$\begin{aligned} \text{TAC} &= \text{Annual capital cost} + \text{Annual operating cost} \\ &= 14253783.05 + 2068500 = 16322283.05 \text{ \$}.\text{yr}^{-1} \end{aligned}$$

So, Total annual cost is targeted as \$ 16322283.05/yr.